



The mentioned product complies with the mentioned test requirement

# Intertek LSS Scheme Tick Mark Certificate

18LHK0194-02

In accordance with the Tick Mark Rules and Certification System 5, as defined in ISO / IEC 17067:2013, we certify that the product(s)

**EV-PYS Optical Smoke Detector with integral Sounder and EV-PYS-DSCI Smoke detector with integral Sounder and Short Circuit Isolator**

is/are in conformity with the following standard(s):

- EN54-3:2001+A1:2002+A2:2006**
- EN54-7:2000+A1:2002+A2:2006**
- EN54-17:2005+AC:2007**

Report Number(s):

102756905LHD-021, 102756905LHD-022 and 102756905LHD-023

**Nittan Europe Limited**  
**Hipley Street, Old Woking, GU22 9LQ, United Kingdom**

and is/are authorised to use the Intertek Tick Mark for the LSS Scheme on the above mentioned product(s)

This certificate is valid until:

**8<sup>th</sup> May 2022**

This Certificate is issued in accordance with the Certification Regulations governing its use and in reliance on the undertaking given by the Licensee, and only extends to the use in respect of the goods produced to an acceptable degree of compliance with the Approval Standard. This Certificate is not transferable and remains the property of Intertek Testing and Certification Ltd.

<b>Limitations:</b>	<b>Certification Body:</b>	ITCL
	<b>LSS Reference:</b>	LSS 0851
	<b>Issued Date:</b>	08/05/2018

Signed on behalf of Intertek, located at Leatherhead, United Kingdom



Certification Officer

Anees Vaheed





# Intertek LSS Scheme Tick Mark Certificate

18LHK0194-02

The mentioned product  
complies with the  
mentioned test requirement

The tested product fulfils the criteria based on the Intertek Tick Mark Specification according to the guideline and is therefore awarded the Intertek Tick Mark. The Intertek Tick Mark may be used by the applicant in connection with sales and marketing in order to demonstrate and verify the performance of the tested product.

## ANNEX No. 1

Brand and Type/Model	Description	Factory Code
EV-PYS	Optical Smoke Detector with integral Sounder	NITTANUK.02
EV-PYS-DSCI	Smoke detector with integral Sounder and Short Circuit Isolator	NITTANUK.02

## ANNEX No. 2

### Bases:

Model	Description
UB-6-EV	Detector Mounting Base
UB-6	Detector Mounting Base

### Complaint Settings:

#### Tones:

Tone No.	Description
1	Default tone – 750/1000 Hz - 0.5/0.5 sec
2	DIN Tone – 1200 – 500 Hz over 1s
3	Dutch tone – 500 – 1200 Hz over 3.5s
4	Continuous – 1000 Hz Continuous
Volume	Maximum

### Smoke sensitivity:

Sensitivity
Low sensitivity
Medium sensitivity
High sensitivity

### Conditions of use:

Suitable for indoor applications only

This Certificate is for the exclusive use of Intertek's Client and is provided pursuant to the Certification agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this certificate. Only the Client is authorised to permit copying or distribution of this certificate and then only in its entirety. Use of Intertek's Certification mark is restricted to the conditions laid out in the agreement. Any further use of the Intertek name for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek. Initial Factory Assessments and Follow up Services are for the purpose of assuring appropriate usage of the Certification mark in accordance with the agreement, they are not for the purposes of production quality control and do not relieve the Client of their obligations in this respect.