

06 July 2018

SENSORTEC Addressable Obsolete Products

Product	Part Number	Description	Replacement	Part Number	Description
NID-58-AS		Addressable Ionisation Smoke	ST-PY-AS UB-4 or UB-6-EV	F15-82100 F03-83500 F03-83521	Addressable Optical Smoke. NOTE: Detector Type code may need updating in the Panel Configuration. Needs Address Programmer MTM-E
2IC-AS	F13-71006				
ST-I-AS	F13-81000				
5000-ION	F13-81010				
ST-I-AS-P	F13-81010				
2KC-AS		Addressable Optical Smoke	ST-PY-AS UB-4 or UB-6-EV	F15-82100 F03-83500 F03-83521	Addressable Optical Smoke. Drop in replacement. Needs Address Programmer MTM-E
2KH-AS	F14-71079				
ST-P-AS	F14-81100				
5000-OP	F14-81100				
ST-P-AS-P	F14-81110				
TCA-AS		Addressable Heat	ST-H2-AS UB-4 or UB-6-EV	F15-81300 F03-83500 F03-83521	Addressable Heat. Drop in Replacement. Needs Address Programmer MTM-E
ST-H-AS	F15-81200				
ST-H-AS-P	F15-81210				
5000-TEMP	F15-81210				
ST-P-AW	F14-81130	Addressable Smoke or Heat (Tyco AW Protocol)	No Replacement		Contact Technical Sales
ST-H-AW	F15-81230				
ST-P-SG		Addressable Smoke or Heat (Signalco SG Protocol)	No Replacement		Contact Technical Sales
ST-H-SG					
ST-NCP-AS	F16-81300	Addressable Call Point	AS-MCP2-IP24	F16-82300	Addressable Indoor Call Point
AS-MCP	F16-82303		AS-MCP2-IP67	F16-82301	Addressable Indoor Call Point
VCT-03-AS	F16-81461	Addressable Base Sounder	AS-ABS	F16-81563	Addressable Base Sounder
NAM-AS3	F16-85110	Addressable Input Module	1IASBOX	F16-81500	Addressable Input Module
OCM-AS3	F16-85115	Addressable Output Module	1OASBOX	F16-81510	Addressable Output Module
SCM-AS4	F16-85125	Addressable Sounder Module	SCM-AS5	F16-81530	Addressable Sounder Module
MCM-AS3	F16-81415	Addressable Zone Monitor	MCM-AS5	F16-81540	Addressable Zone Monitor
MCM-AS4	F16-85120				

NOTE: There are additional variants of the above. If they include "AS", "AW" or "SG" they are Addressable and follow these rules.



David Wright – Technical Support Engineer

TGS-01 – 6th July 2018