

CERTIFICATE OF CONSTANCY OF PERFORMANCE

0359-UKCA-CPR-00002

Construction Products Regulation 2011 (retained EU law EUR 305/2011) as amended by the Construction Products (Amendment etc.) (EU Exit) Regulations 2019 and the Construction Products (Amendment etc.) (EU Exit) Regulations 2020.

Product(s): Short Circuit Isolators
(refer to attached appendix for details and conditions)

placed on the market under the name or trademark of: Nittan Europe Limited
Hiple Street, Old Woking, GU22 9LQ, United Kingdom

and produced in the manufacturing plant(s): Nittan Europe Limited (NITTANUK.02)
Hiple Street, Old Woking, GU22 9LQ, United Kingdom

Intended use: Fire Safety



0359

This certificate attests that all provisions concerning the assessment and verification of constancy of performance described in Annex ZA of the standard(s):

EN54-17:2005+AC:2007

under System 1 for the performance set out in this certificate are applied and that the factory production control conducted by the manufacturer is assessed to ensure the constancy of performance of the construction product.

Approved Body (UK)


This certificate was first issued on **30/11/2021** and will remain valid as long as neither the harmonised standard, the construction product, the AVCP methods nor the manufacturing conditions in the plant are modified significantly, unless suspended or withdrawn by the notified product certification body.

Approved Body
0359

Certification Officer: Andrew Lawson

Date: 30/11/2021

Signature:



Issue: 1

CERTIFICATE OF CONSTANCY OF PERFORMANCE

0359-UKCA-CPR-00002

APPENDIX 1: Certificate of Constancy of Performance 0359-UKCA-CPR-00002

The details and conditions of use for the **Short Circuit Isolators**, placed on the market under the name or trademark of:

Nittan Europe Limited

Hipley Street, Old Woking, GU22 9LQ, United Kingdom

To be used in accordance with the supplier's installation instructions and in conjunction with the following bases, ancillaries, sounder tones, and sensitivity settings (*where applicable*):

Products compliant with **EN54-17:2005+AC:2007**

Model	Manufacturing Location	Product Description
EV-B-SCI	NITTANUK.02	Short-circuit Isolator Base
EV-SPB-SCI	NITTANUK.02	Short-circuit Isolator Base (IP)
EV-DIN-SCI	NITTANUK.02	DIN-rail Mounted Short-circuit Isolator

Conditions of use:

-Model EV-B-SCI has an Ingress protection rating of IP22 and is suitable for Indoor applications.

-Model EV-SPB-SCI has an Ingress protection rating of IP56 and is suitable for Indoor and Outdoor applications.

-Model EV-DIN-SCI has an Ingress protection rating of IP20 and is suitable for Indoor applications.

Where the Model EV-DIN-SCI is installed in an enclosure however, then it could; in accordance with manufacturers instructions; achieve ingress protection rating equivalent to the enclosure into which it is installed.

General Notes:

1. Evaluated under Intertek project number 101139964, G104629169
2. No CE or other type approval is made or inferred outside of the Assessment and Verification of Constancy of Performance as stipulated on this certificate.