



## EC DECLARATION OF PERFORMANCE

No: 1712



This declaration was compiled following the provisions of EU Construction Products Regulation CPR No.305/2011 & UKCA SI 465/2019.

**EV-DP** Analogue Addressable Dual Optical Smoke detector

**Part numbers:** F14-82105

**Compatible Bases:** UB-4, UB-6-EV, STB-4SE, STB-4SE-EV, IP55-Base + Mount  
EV-B-SCI, EV-SPB-SCI, EV-24VRL, SCI-5, EV-SDR Base,  
EV-AV2 Base

**Manufacturer:** Nittan Europe Ltd, Old Woking, Surrey GU22 9LQ England

We, Nittan Europe Limited of Hipley Street, Old Woking, Surrey GU22 9LQ England, declare that the above listed products comply with the following:

Standard EN54-7:2018, Smoke detectors - Point detectors.

EMC Directive 2014/30/EU & Electromagnetic Compatibility Regulations 2016 UK

Low Voltage Directive (LVD) 2014/35/EU & Electrical Equipment (Safety) Regulations 2016 UK

RoHS Directive (EU) 2015/863 & Restriction of the Use of Certain Hazardous Substances in Electrical and Electronic Equipment Regulations 2012 UK

The intended use for the construction product is Fire Detection and Alarm Systems.

DBI Certification, Jernholmen 12 DK-2650 Hvidovre, Notified body number 2531, have conducted Type testing and Factory Production Control Inspection in accordance with System 1, as set out in the CPR, and issued an EC Certificate of Constancy of Performance 2531-CPR-232.1712.

DBI Certification, Northcot Park, Blockley, GL56 9LH Notified body number 8504, have issued the UKCA certification 8504-UKCA-CPR-UKCSP10004 accordance with UKCA SI 465/2019.



# EC DECLARATION OF PERFORMANCE

No: 1712

Declared Performance:

Technical Characteristics	Performance	Harmonised Specification
Operating Voltage	20 V d.c. to 38 V d.c.	EN54-7: 2018
Quiescent Current	200 $\mu$ A	
Alarm Current (Including Indicator)	5 mA	
Remote LED Indicator Current	2 mA	
Operating Temperature	-10°C to +55°C	
Relative Humidity	$\leq$ RH 95%	
Dimensions	$\varnothing$ 104mm x 35.0mm	
Mass	120 g	
<b>Operational Reliability</b>		
Individual alarm indication	PASS	EN54-7: 2018 Clause 4.2.1
Connection of ancillary devices	PASS	EN54-7: 2018 Clause 4.2.2
Monitoring of detachable detectors	PASS	EN54-7: 2018 Clause 4.2.3
Manufacturer's adjustments	PASS	EN54-7: 2018 Clause 4.2.4
On site adjustment of response behaviour	PASS	EN54-7: 2018 Clause 4.2.5
Protection against the ingress of foreign bodies	PASS	EN54-7: 2018 Clause 4.2.6
Response to slowly developing fires	PASS	EN54-7: 2018 Clause 4.2.7
Software controlled detector (when provided)	PASS	EN54-7: 2018 Clause 4.2.8
<b>Nominal activation conditions/Sensitivity</b>		
Repeatability	PASS	EN54-7: 2018 Clause 4.3.1
Directional dependence	PASS	EN54-7: 2018 Clause 4.3.2
Reproducibility	0.21 to 0.24 dB/m	EN54-7: 2018 Clause 4.3.3
<b>Response delay (response time)</b>		
Air movement	PASS	EN54-7: 2018 Clause 4.4.1
Dazzling	PASS	EN54-7: 2018 Clause 4.4.2
<b>Tolerance to supply voltage:</b>		
Variation in supply parameters	PASS	EN54-7: 2018 Clause 4.5
<b>Performance parameters under fire conditions:</b>		
Fire sensitivity	PASS	EN54-7: 2018 Clause 4.6
<b>Durability – Temperature resistance:</b>		
Cold (operational)	PASS	EN54-7: 2018 Clause 4.7.1.1
Dry heat (operational)	PASS	EN54-7: 2018 Clause 4.7.1.2
<b>Durability – Humidity resistance:</b>		
Damp heat, steady-state (operational)	PASS	EN54-7: 2018 Clause 4.7.2.1
Damp heat, steady-state (endurance)	PASS	EN54-7: 2018 Clause 4.7.2.2
<b>Durability – Corrosion resistance:</b>		
Sulfur dioxide (SO <sub>2</sub> ) corrosion (endurance)	PASS	EN54-7: 2018 Clause 4.7.3
<b>Durability – Vibration resistance:</b>		
Shock (operational)	PASS	EN54-7: 2018 Clause 4.7.4.1
Impact (operational)	PASS	EN54-7: 2018 Clause 4.7.4.2
Vibration, sinusoidal (operational)	PASS	EN54-7: 2018 Clause 4.7.4.3
Vibration, sinusoidal (endurance)	PASS	EN54-7: 2018 Clause 4.7.4.4
<b>Durability – Electrical stability:</b>		
EMC, immunity (operational)	PASS	EN54-7: 2018 Clause 4.7.5



## EC DECLARATION OF PERFORMANCE

No: 1712

Barry Sargent  
Technical Product Manager

31<sup>st</sup> March 2022

