



The mentioned product
complies with the mentioned
test requirement

Intertek LSS Scheme Tick Mark Certificate

19LHK0665-01

This is to certify that:

Nittan Evolution Range of Smoke and Heat Detectors

Is in conformity with the following standard(s):

EN54-5:2017+A1:2018, EN54-7:2018, EN54-17:2005+AC:2007, EN54-29:2015

Report Number(s):

104165000LHD-021 Issue 2, 104165000LHD-022 Issue 3,
104165000LHD-023 Issue 2, 104165000LHD-024 Issue 2

Nittan Europe Limited

Hiple Street, Old Woking, Surrey, GU22 9LQ, United Kingdom

and is authorised to use the Intertek Tick Mark for the LSS Scheme on the
above mentioned product(s)

This certificate is valid until:

21 December 2026

This Certificate is issued in accordance with the Certification Regulations governing its use and in reliance on the undertaking given by the Licensee and only extends to the use in respect of the goods produced to an acceptable degree of compliance with the Approval Standard. This Certificate is not transferable and remains the property of Intertek Testing and Certification Ltd.

Limitations: See ANNEX No. 2	Certification Body: ITCL LSS Reference: LSS 1006 Issued Date: 21 December 2022
--	---

Signed on behalf of Intertek, located at Leatherhead, United Kingdom



Certification Officer

Andrew Lawson



Intertek LSS Scheme Tick Mark Certificate

19LHK0665-01

The mentioned product complies with the mentioned test requirement

The tested product fulfils the criteria based on the Intertek Tick Mark Specification according to the guideline and is therefore awarded the Intertek Tick Mark. The Intertek Tick Mark may be used by the applicant in connection with sales and marketing in order to demonstrate and verify the performance of the tested product.

0010

ANNEX No. 1

Brand / Model	Description	Factory Code
Nittan EV-H2-A1R	Analogue Addressable Heat Detector	NITTANUK.02
Nittan EV-H2-CS	Analogue Addressable Heat Detector	NITTANUK.02
Nittan EV-H2-SCI	Analogue Addressable Heat Detector + Short-circuit Isolator (SCI)	NITTANUK.02
Nittan EV-PY	Analogue Addressable Smoke Detector	NITTANUK.02
Nittan EV-PY-SCI	Analogue Addressable Smoke Detector + Short-circuit Isolator (SCI)	NITTANUK.02
Nittan EV-PYH	Analogue Addressable Smoke and Heat Detector	NITTANUK.02
Nittan EV-PYH-SCI	Analogue Addressable Smoke and Heat Detector + Short-circuit Isolator (SCI)	NITTANUK.02

ANNEX No. 2

Conditions of use:

Suitable for indoor applications only.

General notes:

1. Evaluated under Intertek project number G104165000.
2. No CE or other type approval is made or inferred outside of the attestation of conformity and the product performance as stipulated on this certificate.