

CERTIFICATE OF CONSTANCY OF PERFORMANCE

0359-UKCA-CPR-00009

Construction Products Regulation 2011 (retained EU law EUR 305/2011) as amended by the Construction Products (Amendment etc.) (EU Exit) Regulations 2019 and the Construction Products (Amendment etc.) (EU Exit) Regulations 2020.

Product(s): EV-PYS Optical Smoke Detector with Integral Sounder
(refer to attached appendix for details and conditions)

placed on the market
under the name or trademark of: Nittan Europe Limited
Hiple Street, Old Woking, GU22 9LQ, United Kingdom

and produced in the
manufacturing plant(s): Nittan Europe Limited
Hiple Street, Old Woking, GU22 9LQ, United Kingdom

Intended use: Fire Safety



0359

This certificate attests that all provisions concerning the assessment and verification of constancy of performance described in Annex ZA of the standard(s):

EN54-3:2001+A1:2002+A2:2006
EN54-7:2018

under System 1 for the performance set out in this certificate are applied and that the factory production control conducted by the manufacturer is assessed to ensure the constancy of performance of the construction product.

Approved Body (UK)

This certificate was first issued on **23-09-2021** and will remain valid as long as neither the harmonised standard, the construction product, the AVCP methods nor the manufacturing conditions in the plant are modified significantly, unless suspended or withdrawn by the notified product certification body.

Approved Body
0359

Certification Officer: Andrew Lawson

Date: 21-09-2022

Signature:



Issue: 2

CERTIFICATE OF CONSTANCY OF PERFORMANCE

0359-UKCA-CPR-00009

APPENDIX 1: Certificate of Constancy of Performance 0359-UKCA-CPR-00009

The details and conditions of use for the **EV-PYS Optical Smoke Detector with Integral Sounder**, placed on the market under the name or trademark of:

Nittan Europe Limited

Hipley Street, Old Woking, GU22 9LQ, United Kingdom

To be used in accordance with the supplier's installation instructions and in conjunction with the following bases, ancillaries, sounder tones and sensitivity settings (*where applicable*):

Products compliant with **EN54-3:2001+A1:2002+A2:2006 and EN54-7:2018**

Model	Manufacturing Location	Product Description
EV-PYS	NITTANUK.01	Optical Smoke Detector and Integral Sounder

Bases:

UB-6-EV	Detector Mounting Base
UB-6	Detector Mounting Base
EV-PYSVAD	Beacon VAD Base

Approved Settings:

Tones:

Tone No.	Description
1	Default tone – 750/1000 Hz – 0.5/0.5 sec
2	DIN tone – 1200 – 500 Hz over 1s
3	Dutch tone – 500 – 1200 Hz over 3.5sec
4	Continuous – 1000 Hz Continuous
Volume	Maximum

Smoke Sensitivity:

Low
Medium
High

This Certificate is for the exclusive use of Intertek's client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this Certificate. Only the Client is authorized to permit copying or distribution of this Certificate and then only in its entirety. Any use of the Intertek name or one of its marks for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek. This Certificate is Accredited under UKAS Schedule 0010.
Intertek Testing & Certification Limited, Cleeve Road, Leatherhead, Surrey, KT22 7SA
Registered No 3272281 Registered Office: Academy Place, 1-9 Brook Street, Brentwood, Essex, CM14 5NQ.

CERTIFICATE OF CONSTANCY OF PERFORMANCE

0359-UKCA-CPR-00009


APPENDIX 1: Certificate of Constancy of Performance 0359-UKCA-CPR-00009

Conditions of use:

Suitable for indoor applications only.

General Notes:

1. Evaluated under Intertek project number G102756905 and G105053554.
2. No CE or other type approval is made or inferred outside of the Assessment and Verification of Constancy of Performance as stipulated on this certificate.



This Certificate is for the exclusive use of Intertek's client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this Certificate. Only the Client is authorized to permit copying or distribution of this Certificate and then only in its entirety. Any use of the Intertek name or one of its marks for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek. This Certificate is Accredited under UKAS Schedule 0010.
Intertek Testing & Certification Limited, Cleeve Road, Leatherhead, Surrey, KT22 7SA
Registered No 3272281 Registered Office: Academy Place, 1-9 Brook Street, Brentwood, Essex, CM14 5NQ.