

CERTIFICATE OF CONSTANCY OF PERFORMANCE

0905-CPR-00114

In compliance with Regulation (EU) No 305/2011 of the European Parliament and of the Council of 9 March 2011 (the Construction Products Regulation or CPR), this certificate applies to the construction product(s)

Product(s): Range of Input / Output Modules for use in fire detection and fire alarm systems

(refer to attached appendix for details and conditions)

Placed on the market under the name or trade mark of: Nittan Europe Limited
Hiplely Street
Old Woking, GU22 9LQ
United Kingdom

and produced in the manufacturing plant(s): Nittan Europe Limited (SG- 12020)
Hiplely Street
Old Woking, GU22 9LQ
United Kingdom

Intended use: Fire Safety

This certificate attests that all provisions concerning the assessment and verification of constancy of performance described in Annex ZA of the standard(s):

EN 54-18:2005+AC:2007

Under System 1 for the performance set out in this certificate are applied and that the performance of the construction product is assessed to remain constant.

This certificate was first issued under **0359-CPR-00114** on **2011-09-28** and will remain valid as long as neither the harmonised standard, the construction product, the AVCP methods nor the manufacturing conditions in the plant are modified significantly, unless suspended or withdrawn by the notified product certification body.

Notified Body

0905

Certification Manager: Dipl.-Ing. Roland Heine

Date Issue: 2019-10-14

Issue: 1

Signature:



CERTIFICATE OF CONSTANCY OF PERFORMANCE

0905-CPR-00114

APPENDIX TO: Certificate of Constancy of Performance 0905-CPR-00114

The details and conditions of use for the Range of Input / Output Modules for use in fire detection and fire alarm systems , placed on the market under the name or trade mark of:

Nittan Europe Limited
Hiple Street
Old Woking, GU22 9LQ
United Kingdom

To be used in accordance with the supplier's installation instructions and in conjunction with the following bases, ancillaries, sounder tones and sensitivity settings (*where applicable*):
Products compliant with EN 54-18:2005+AC:2007

Model	Manufacturing Location	Description
EV I/P	SG-12020	Addressable Input Module
EV-Mini I/P	SG-12020	Addressable Mini Input Module
EV-ZMU	SG-12020	Zone Monitor Unit
EV-SIO	SG-12020	Addressable Single Input/Output Module
EV-OP	SG-12020	Addressable Output Module
EV-SCM	SG-12020	Sounder Control Module
EV-SBM	SG-12020	Sounder Booster Module

Conditions of use:

Suitable for indoor applications only.

General Notes:

1. Evaluated under Intertek project number 10050175.
2. No CE or other type approval is made or inferred outside of the attestation of conformity and the product performance as stipulated on this certificate.