

CERTIFICATE OF CONSTANCY OF PERFORMANCE

0359-UKCA-CPR-00010

Construction Products Regulation 2011 (retained EU law EUR 305/2011) as amended by the Construction Products (Amendment etc.) (EU Exit) Regulations 2019 and the Construction Products (Amendment etc.) (EU Exit) Regulations 2020.

Product(s): EV Range of Input/ Output Modules
(refer to attached appendix for details and conditions)

placed on the market under the name or trademark of: Nittan Europe Limited
Hipley Street, Old Woking, GU22 9LQ, United Kingdom

and produced in the manufacturing plant(s): Nittan Europe Limited (NITTANUK.02)
Hipley Street, Old Woking, GU22 9LQ, United Kingdom

Intended use: Fire Safety



0359

Approved Body (UK)

This certificate attests that all provisions concerning the assessment and verification of constancy of performance described in Annex ZA of the standard(s):

EN 54-18:2005+AC:2007
EN 54-17:2005+AC:2007

Under System 1 for the performance set out in this certificate are applied and that the factory production control conducted by the manufacturer is assessed to ensure the constancy of performance of the construction product.

This certificate was first issued on **30/11/2021** and will remain valid as long as neither the harmonised standard, the construction product, the AVCP methods nor the manufacturing conditions in the plant are modified significantly, unless suspended or withdrawn by the notified product certification body.

Approved Body
0359

Certification Officer: Andrew Lawson

Date: 30/11/2021

Signature:

Issue: 1

CERTIFICATE OF CONSTANCY OF PERFORMANCE

0359-UKCA-CPR-00010

APPENDIX 1: Certificate of Constancy of Performance 0359-UKCA-CPR-00010

The details and conditions of use for the **EV Range of Input/ Output Modules**, placed on the market under the name or trademark of:

Nittan Europe Limited

Hipley Street, Old Woking, GU22 9LQ, United Kingdom

To be used in accordance with the supplier's installation instructions and in conjunction with the following bases, ancillaries, sounder tones, and sensitivity settings (*where applicable*):

| Model | Manufacturing Location | Product Description |
|-------|------------------------|---------------------|
|-------|------------------------|---------------------|

Products compliant with EN54-17:2005+AC:2007 and EN54-18:2005+AC:2007:

| | | |
|------------|-------------|--|
| EV-2I10 | NITTANUK.02 | Dual Input, Single Output Module (240V Mains Rated) with Integral Short-circuit Isolator |
| EV-2I10-EU | NITTANUK.02 | Dual Input, Single Output Module (240V Mains Rated) with Integral short-circuit Isolator, European Version |
| EV-3IO | NITTANUK.02 | Triple Input/ Output Module (One 240V Mains Rated Relay) with Integral Short-circuit Isolator |
| EV-MiniIP2 | NITTANUK.02 | Mini Input Module with Integral Short-circuit Isolator |
| EV-SCM2 | NITTANUK.02 | Dual Output Sounder Control Module with Integral Short-circuit Isolator |
| EV-SCM2-EU | NITTANUK.02 | Dual Output Sounder Control Module with Integral Short-circuit Isolator, European Version |
| EV-ZMU2 | NITTANUK.02 | Dual Input Zone Monitor Module with Integral Short-circuit Isolator |
| EV-ZMU2-EU | NITTANUK.02 | Dual Input Zone Monitor Module with Integral Short-circuit Isolator, European Version |
| EV-IO-420 | NITTANUK.02 | 4-20mA Input / Output Module (240V Mains Rated) with Integral Short-circuit Isolator |

Products compliant with EN54-18:2005+AC:2007:

| | | |
|----------|-------------|--|
| EV-24VRL | NITTANUK.02 | Detector Base with Latching Relay Output |
|----------|-------------|--|

Conditions of use:

Suitable for Indoor applications only

General Notes:

1. Evaluated under Intertek project number 102788845, G104629169
2. No CE or other type approval is made or inferred outside of the attestation of conformity and the product performance as stipulated on this certificate.

This Certificate is for the exclusive use of Intertek's client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this Certificate. Only the Client is authorized to permit copying or distribution of this Certificate and then only in its entirety. Any use of the Intertek name or one of its marks for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek. This Certificate is Accredited under UKAS Schedule 0010.
Intertek Testing & Certification Limited, Cleeve Road, Leatherhead, Surrey, KT22 7SA
Registered No 3272281 Registered Office: Academy Place, 1-9 Brook Street, Brentwood, Essex, CM14 5NQ.