CERTIFICATE OF COMPLIANCE

Certificate Number \$25165

Report Reference S25165-2021-10-22

Date 2021-November-08

Issued to: NITTAN CO LTD

54-5, 1-CHOME SASAZUKA

SHIBUYA-KU TOKYO 151-8535 JP

This is to certify that representative samples of

HEAT-AUTOMATIC FIRE DETECTORS

See Addendum Page for Product Designation(s).

Have been investigated by UL in accordance with the

Standard(s) indicated on this Certificate.

Standard(s) for Safety: ANSI/UL 521 - Heat Detectors for Fire Protective Signaling

Systems

Additional Information: See the UL Online Certifications Directory at

https://ig.ulprospector.com for additional information

This Certificate of Compliance does not provide authorization to apply the UL Mark. Only the UL Follow-Up Services Procedure provides authorization to apply the UL Mark.

Only those products bearing the UL Mark should be considered as being UL Certified and covered under UL's Follow-Up Services.

Look for the UL Certification Mark on the product.





CERTIFICATE OF COMPLIANCE

Certificate Number S25165

Report Reference \$25165-2021-10-22

Date 2021-November-08

This is to certify that representative samples of the product as specified on this certificate were tested according to the current UL requirements

Fire Alarm Subassembly:

USL - Heat Detector head, intelligent (addressable), Model EVA-H3 combination 135 °F (57.2 °C) fixed temperature and 15 °F/min (8.3 °C/min) rate of rise.

USL - Heat Detector head, intelligent (addressable), Model EVA-H3-H 181.4 $^{\circ}$ F (83.0 $^{\circ}$ C) fixed temperature.







