



## EC & UKCA DECLARATION OF PERFORMANCE

No: F4882



This declaration was compiled following the provisions of EU Construction Products Regulation CPR No.305/2011 & UKCA SI 465/2019

**EVC-DP** Conventional Dual Optical Smoke Detector

**Part number:** F02-82215

**Compatible Bases:** UB-4, UB-6-EV, STB-4SE & UB-4SD

**Manufacturer:** Nittan ASEAN Co Ltd, Standard Factory No. 9C&D, Lot H-1, Thang Long II Industrial Park, Di Su Commune, My Hao Town, Hung Yen Province, Vietnam.

We, Nittan Europe Limited of Hipley Street, Old Woking, Surrey GU22 9LQ England, declare that the above listed product complies with the following:

Standard EN54-7:2018, Smoke detectors - Point detectors.

EMC Directive 2014/30/EU & Electromagnetic Compatibility Regulations 2016 UK

RoHS Directive (EU) 2015/863 & Restriction of the Use of Certain Hazardous Substances in Electrical and Electronic Equipment Regulations 2012 UK

Low Voltage Directive (LVD) 2014/35/EU & Electrical Equipment (Safety) Regulations 2016 UK

The intended use for the construction product is Fire Detection and Alarm Systems.

BRE Global Assurance (Ireland) LTD, DCU Alpha, Old Finglas Road, Glasnevin, Dublin, D11 KXN4, Ireland, Notified body number 2831, have conducted Type testing and Factory Production Control Inspection in accordance with System 1, as set out in the CPR, and issued an EC Certificate of Constancy of Performance 2831-CPR-F4882.

BRE Global Assurance UK LTD, Bucknalls Lane, Watford, Hertfordshire, WD25 9XX, Notified body number 0832, have issued the UKCA certification 0832-UKCA CPR-F1806 in accordance with UKCA SI 465/2019.



# EC & UKCA DECLARATION OF PERFORMANCE

No: F4882

Declared Performance:

Technical Characteristics	Performance	Harmonised Specification
Operating Voltage	16 Vdc to 32 Vdc	EN54-7: 2018
Quiescent Current	40 $\mu$ A @ 24 Vdc	
Alarm Current (Including Indicator)	50 mA @ 24 Vdc	
Remote LED Indicator Current	2 mA	
Operating Temperature	-10°C to +55°C	
Relative Humidity	$\leq$ RH 95%	
Dimensions	$\varnothing$ 104.5mm x 35mm	
Mass	130 g	
<b>Operational Reliability</b>		<b>EN54-7: 2018</b>
Individual alarm indication	PASS	EN54-7: 2018 Clause 4.2.1
Connection of ancillary devices	PASS	EN54-7: 2018 Clause 4.2.2
Monitoring of detachable detectors	PASS	EN54-7: 2018 Clause 4.2.3
Manufacturer's adjustments	PASS	EN54-7: 2018 Clause 4.2.4
On site adjustment of response behaviour	PASS	EN54-7: 2018 Clause 4.2.5
Protection against the ingress of foreign bodies	PASS	EN54-7: 2018 Clause 4.2.6
Response to slowly developing fires	PASS	EN54-7: 2018 Clause 4.2.7
Software controlled detector (when provided)	PASS	EN54-7: 2018 Clause 4.2.8
<b>Nominal activation conditions/Sensitivity</b>		
Repeatability	PASS	EN54-7: 2018 Clause 4.3.1
Directional dependence	PASS	EN54-7: 2018 Clause 4.3.2
Reproducibility	0.21 to 0.33 dB/m	EN54-7: 2018 Clause 4.3.3
<b>Response delay (response time)</b>		
Air movement	PASS	EN54-7: 2018 Clause 4.4.1
Dazzling	PASS	EN54-7: 2018 Clause 4.4.2
<b>Tolerance to supply voltage:</b>		
Variation in supply parameters	PASS	EN54-7: 2018 Clause 4.5
<b>Performance parameters under fire conditions:</b>		
Fire sensitivity TF-2, TF-3, TF-4 & TF5	PASS	EN54-7: 2018 Clause 4.6
<b>Durability – Temperature resistance:</b>		
Cold (operational)	PASS	EN54-7: 2018 Clause 4.7.1.1
Dry heat (operational)	PASS	EN54-7: 2018 Clause 4.7.1.2
<b>Durability – Humidity resistance:</b>		
Damp heat, steady-state (operational)	PASS	EN54-7: 2018 Clause 4.7.2.1
Damp heat, steady-state (endurance)	PASS	EN54-7: 2018 Clause 4.7.2.2
<b>Durability – Corrosion resistance:</b>		
Sulfur dioxide (SO <sub>2</sub> ) corrosion (endurance)	PASS	EN54-7: 2018 Clause 4.7.3
<b>Durability – Vibration resistance:</b>		
Shock (operational)	PASS	EN54-7: 2018 Clause 4.7.4.1
Impact (operational)	PASS	EN54-7: 2018 Clause 4.7.4.2
Vibration, sinusoidal (operational)	PASS	EN54-7: 2018 Clause 4.7.4.3
Vibration, sinusoidal (endurance)	PASS	EN54-7: 2018 Clause 4.7.4.4
<b>Durability – Electrical stability:</b>		
EMC, immunity (operational)	PASS	EN54-7: 2018 Clause 4.7.5



## EC & UKCA DECLARATION OF PERFORMANCE

No: F4882

Barry Sargent  
Technical Product Manager  
11<sup>th</sup> August 2024

