

EC DECLARATION OF PERFORMANCE

No: E0029



This declaration was compiled following the provisions of EU Construction Products Regulation CPR No.305/2011 & UKCA SI 465/2019.

Product Type - evo+5000 Series of Fire Detection & Fire Alarm Panels

Part numbers:

| | | Loops |
|----------|---|---------|
| evo+5100 | evo5101, evo5101M, evo5101L, evo5101D, evo5101R | 1 |
| evo+5200 | evo520x, evo542xL, evo520xD, evo520xR | x = 1-2 |
| evo+5400 | evo540x, evo540xL, evo540xD, evo540xR | x = 1-4 |
| evo+5800 | evo580x | x = 2-8 |

Manufacturer: The Bridges, Balliol Business Park Longbenton, North Tyneside NE12 8EW, England.

We, Nittan Europe Limited of Hipley Street, Old Woking, Surrey GU22 9LQ England, declare that the above listed products comply with the following Harmonised Standards:

Standard EN54-2:1997 + A1:2006, Control & Indicating Equipment.

Standard EN54-4:1997 + A1:2002 + A2:2006, Power Supply Equipment.

Standard EN54-13: 2005, Compatibility Assessment of System Components

EMC Directive 2014/30/EU & Electromagnetic Compatibility Regulations 2016 UK

RoHS Directive (EU) 2015/863 & Restriction of the Use of Certain Hazardous Substances in Electrical and Electronic Equipment Regulations 2012 UK

The intended use for the construction product is Fire Detection and Alarm Systems.

FM Approvals Europe Limited, One Georges Quay Plaza, Dublin. Ireland. D02 E440 Notified body number 2809, have conducted Type Test assessment and Factory Production Control Inspection in accordance with System 1, as set out in the CPR, and issued an EC Certificate of Constancy of Performance 2809-CPR-E0029.

FM Approvals Ltd, Voyager Place, Maidenhead, Berkshire, SL6 2PJ with Approved body number 1725, have issued the UKCA Certificate of Constancy of Performance 1725- CPR-UKE1010 in accordance with UKCA SI 465/2019.

EC DECLARATION OF PERFORMANCE No: E0029

Declared Performance:

| Essential Characteristic | Performance | Harmonised technical specification | |
|--|-------------|--|--|
| Performance under fire conditions | Pass | EN54-2:1997 +A1:2006, Clauses 4, 5, 7 | |
| Response delay (response time to fire) | Pass | EN54-2:1997 +A1:2006, Clauses 7.1, 7.7, 7.11, 7.12 | |
| Operational reliability | | | |
| General requirements | Pass | EN54-2:1997 +A1:2006, Clause 4 | |
| General requirements for indications | Pass | EN54-2:1997 +A1:2006, Clause 5 | |
| The quiescent condition | Pass | EN54-2:1997 +A1:2006, Clause 6 | |
| The fire alarm condition | Pass | EN54-2:1997 +A1:2006, Clauses 7.1, 7.2, 7.3, 7.4, 7.5, 7.6, 7.7 | |
| Output to fire alarm devices | Pass | EN54-2:1997 +A1:2006, Clause 7.8 | |
| Control of fire alarm routing equipment | Pass | EN54-2:1997 +A1:2006, Clause 7.9 | |
| Outputs to fire protection equipment | Pass | EN54-2:1997 +A1:2006, Clause 7.10 | |
| Delays to outputs | Pass | EN54-2:1997 +A1:2006, Clause 7.11 | |
| Dependencies on more than one alarm signal | Pass | EN54-2:1997 +A1:2006, Clause 7.12 | |
| Alarm Counter | Pass | EN54-2:1997 +A1:2006, Clause 7.13 | |
| The fault warning condition | Pass | EN54-2:1997 +A1:2006, Clauses 8.1, 8.2, 8.3, 8.5, 8.6, 8.7, 8.8 | |
| Total loss of power supply | NPD | EN54-2:1997 +A1:2006, Clause 8.4 | |
| Output to fault warning routing equipment | Pass | EN54-2:1997 +A1:2006, Clause 8.9 | |
| Disablement of addressable points | Pass | EN54-2:1997 +A1:2006, Clause 9.5 | |
| Test condition | Pass | EN54-2:1997 +A1:2006, Clause 10 | |
| Standardised input / output interface | Pass | EN54-2:1997 +A1:2006, Clause 11 | |
| Design requirements | Pass | EN54-2:1997 +A1:2006, Clause12 | |
| Additional design requirements for software controlled control and indicating equipment | Pass | EN54-2:1997 +A1:2006, Clause 13 | |
| Marking | Pass | EN54-2:1997 +A1:2006, Clause 14 | |
| Operational reliability | Pass | EN54-4:1997 +A1:2002+A2:2006, Clauses 4, 5, 6, 7, 8 | |
| Performance of power supply | Pass | EN54-4:1997 +A1:2002+A2:2006, Clauses 4, 5, 6 | |
| Durability of operational reliability, Temperature | Pass | EN54-2:1997 +A1:2006, Clause 15.4 | |
| resistance | | EN54-4:1997 +A1:2002+A2:2006, Clause 9.5 | |
| Durability of operational reliability, Vibration | Pass | EN54-2:1997 +A1:2006, Clauses 15.6, 15.7, 15.15 | |
| resistance | | EN54-4:1997 +A1:2002+A2:2006, Clauses 9.7, 9.8, 9.15 | |
| Durability of operational reliability, Electrical | Pass | EN54-2:1997 +A1:2006, Clauses 15.8 to 15.13 | |
| stability | | EN54-4:1997 +A1:2002+A2:2006, Clauses 9.9 to 9.13 | |
| Durability of operational reliability, Humidity resistance | Pass | EN54-2:1997 +A1:2006, Clauses 15.5, 15.14 EN54-4:1997 +A1:2002+A2:2006, Clauses 9.6, 9.14 | |
| Basic System Requirements | Pass | EN54-13: 2005 Clause 4.2 | |
| Network Systems | Pass | EN54-13: 2005 Clause 4.3 | |
| Components | Pass | EN54-13: 2005 Clause 4.4 | |
| Transmission Path | Pass | EN54-13: 2005 Clause 4.5 | |
| Input & Output Devices linked to fire protection systems. | Pass | EN54-13: 2005 Clause 4.6 | |

The performance of the product(s) identified in points 1 and 2 is (are) in conformity with the declared performance detailed above. This declaration of performance is issued under the sole responsibility of the manufacturer as identified above. Signed for and on behalf of the manufacturer by:

Barry Sargent Technical Product Manager 16th November 2022



Nittan Europe Ltd, Hipley Street, Old Woking, Surrey GU22 9LQ England Tel: +44 1483 769555 Fax: +44 1483 598506 Web: www.nittan.co.uk