

# CERTIFICATE OF CONSTANCY OF PERFORMANCE

**0905-CPR-00497**

In compliance with Regulation (EU) No 305/2011 of the European Parliament and of the Council of 9 March 2011 (the Construction Products Regulation or CPR), this certificate applies to the construction product(s)

**Product(s):** ST-H2-AS Analogue Addressable Heat Detector  
(refer to attached appendix for details and conditions)

**Placed on the market under the name or trade mark of:** Nittan Europe Limited  
Hipley Street  
Old Woking, GU22 9LQ  
United Kingdom

**and produced in the manufacturing plant(s):** Nittan Europe Limited (SG- 12020)  
Hipley Street  
Old Woking, GU22 9LQ  
United Kingdom

**Intended use:** Fire Safety

This certificate attests that all provisions concerning the assessment and verification of constancy of performance described in Annex ZA of the standard(s):

**EN 54-5:2017+A1:2018**

Under System 1 for the performance set out in this certificate are applied and that the performance of the construction product is assessed to remain constant.

This certificate was first issued under **0905-CPR-00497** on **2019-08-01** and will remain valid as long as neither the harmonised standard, the construction product, the AVCP methods nor the manufacturing conditions in the plant are modified significantly, unless suspended or withdrawn by the notified product certification body.

## Notified Body 0905

**Certification Manager:** Dipl.-Ing. Bernhard Miedtank

**Date Issue:** 2022-09-07

**Issue:** 2

**Signature:**

# CERTIFICATE OF CONSTANCY OF PERFORMANCE

0905-CPR-00497

## APPENDIX TO: Certificate of Constancy of Performance 0905-CPR-00497

The details and conditions of use for the ST-H2-AS Analogue Addressable Heat Detector, placed on the market under the name or trade mark of:

**Nittan Europe Limited**  
**Hipley Street**  
**Old Woking, GU22 9LQ**  
**United Kingdom**

To be used in accordance with the supplier's installation instructions and in conjunction with the following bases, ancillaries, sounder tones and sensitivity settings (*where applicable*):

**Products compliant with EN 54-5:2017+A1:2018**

Model	Manufacturing Location	Description
ST-H2-AS	SG-12020	Analogue addressable heat detector, Class A2S
<b>Bases:</b>		
Model	Description	
UB-4	Standard Base	
UB-6-EV	Standard Base	
STB-4SE	Deep Base	
SCI-5	Isolator Base	
AS-ABS	Sounder Base	

### Conditions of use:

Suitable for indoor applications.

### General Notes:

1. Evaluated under Intertek project number G103263024 and G105053554.
2. No CE or other type approval is made or inferred outside of the attestation of conformity and the product performance as stipulated on this certificate.