

## BRE Global

### UK Approved Body No. 0832

BRE Global Limited  
Bucknalls Lane, Garston, Watford,  
Hertfordshire, UK, WD25 9XX  
Telephone: +44 (0) 333 321 8811  
Fax: +44 (0)1923 664603  
Email: [enquiries@breglobal.com](mailto:enquiries@breglobal.com)  
Web: [www.breglobal.com](http://www.breglobal.com)

## Certificate of UKCA approval constancy of performance 0832-UKCA-CPR-F0040

In compliance with the Construction Product Regulations 2020, UK Statutory Instruments 2020 No.1359 of Ministry of Housing, Communities and Local Government. This certificate applies to the construction product.

### ST-P-OM Conventional Optical Smoke Detector

(For full product details and conditions of use refer to appendix)

Placed on the market under the name or trademark of: and produced in the manufacturing plant(s):

**Nittan Europe Limited**  
Hiple Street  
Old Woking  
Surrey  
GU22 9LQ  
United Kingdom

**Nittan Asean Co Ltd**  
Factory No 9C & D, Lot H-1  
Thang Long II Industrial Park  
Di Su Commune, My Hao District  
Hung Yen Province  
Vietnam

This certificate attests that all provisions concerning the assessment and verification of constancy of performance described in Annex ZA of the standard(s)

### EN 54-7:2018 Smoke Detectors – Point Detectors

under system 1 for the performance set out in this certificate are applied and that the factory production control conducted by the manufacturer is assessed to ensure

### the constancy of performance of the construction product.

This certificate was first issued on 19 August 2021 and will remain valid as long as neither the designated standard, the construction product, the AVCP methods nor the manufacturing conditions in the plant are modified significantly, unless suspended or withdrawn by the approved product certification body.



P. Halligan, Technical Manager

On behalf of BRE Global Limited

Date of First Issue: 19 August 2021

Issue Date: 13 May 2022

Issue Number: 02

To check the validity of this certificate, please contact us on +44 (0)333 321 8811 or email [enquiries@breglobal.com](mailto:enquiries@breglobal.com)

## BRE Global

## UK Approved Body No. 0832

BRE Global Limited  
Bucknalls Lane, Garston, Watford,  
Hertfordshire, UK, WD25 9XX  
Telephone: +44 (0) 333 321 8811  
Fax: +44 (0)1923 664603  
Email: [enquiries@breglobal.com](mailto:enquiries@breglobal.com)  
Web: [www.breglobal.com](http://www.breglobal.com)

## APPENDIX to Certificate of constancy of performance: 0832-UKCA-CPR-F0040

### ST-P-OM Conventional Optical Smoke Detector

#### Bases:

STB-4SE-EV - Standard deep mounting base  
STB-4SE-24VR - Relay mounting base  
STB-4SE - Standard deep mounting base  
UB-4 - Universal mounting base  
UB-4R-470 - Standard base with 470-ohm resistor  
UB-4SDR-470 - Standard base with schottky diode and 470-ohm resistor  
UB-6-EV - Universal mounting base



P. Halligan, Technical Manager

On behalf of BRE Global Limited

Date of First Issue: 19 August 2021

Issue Date: 13 May 2022

Issue Number: 02

To check the validity of this certificate, please contact us on +44 (0)333 321 8811 or email [enquiries@breglobal.com](mailto:enquiries@breglobal.com)