

## BRE Global Ireland

**Notified Body No. 2831**  
BRE Global Assurance (Ireland) Limited  
DCU Alpha, Old Finglas Road  
Glasnevin, Dublin, D11 KXN4  
Ireland  
T: +353 (0) 18824344  
E: [enquiries@breglobalireland.ie](mailto:enquiries@breglobalireland.ie)  
[www.breglobalireland.ie](http://www.breglobalireland.ie)

### Certificate of constancy of performance 2831-CPR-F2428

In compliance with Regulation (EU) No. 305/2011 of the European Parliament and of the Council of 9th March 2011 (the Construction Products Regulation or CPR), this certificate applies to the construction product(s).

#### ST-P-OM Conventional Photoelectric Smoke Detector

*(For full product details and conditions of use refer to appendix)*

Placed on the market under the name or trademark of: and produced in the manufacturing plant(s):

**Nittan Europe Limited**  
**Hipley Street**  
**Old Woking**  
**Surrey**  
**GU22 9LQ**  
**United Kingdom**

**CC0365**

This certificate attests that all provisions concerning the assessment and verification of constancy of performance described in Annex ZA of the standard(s)

#### EN 54-7:2018 - Smoke detectors - Point smoke detectors

under system 1 for the performance set out in this certificate are applied and that the factory production control conducted by the manufacturer is assessed to ensure

#### **the constancy of performance of the construction product.**

This certificate was first issued on 29 October 2019 and will remain valid as long as neither the harmonised standard, the construction product, the AVCP methods nor the manufacturing conditions in the plant are modified significantly, unless suspended or withdrawn by the notified product certification body.

Zsuzsanna Major, Certification Engineer

On behalf of BRE Global Assurance (Ireland) Limited

Date of First Issue: 29 October 2019

Issue Date: 11 February 2026

Issue Number: 03

To check the validity of this certificate, please contact us on +353 (0) 18824344 or email [enquiries@breglobalireland.ie](mailto:enquiries@breglobalireland.ie)

**BRE Global Ireland**

**Approved Body No. 2831**  
BRE Global Assurance (Ireland) Limited  
DCU Alpha, Old Finglas Road  
Glasnevin, Dublin, D11 KXN4  
Ireland  
T: +353 (0) 18824344  
E: [enquiries@breglobalireland.ie](mailto:enquiries@breglobalireland.ie)  
[www.breglobalireland.ie](http://www.breglobalireland.ie)

**APPENDIX to Certificate of constancy of performance: 2831-CPR-F2428**

**ST-P-OM Conventional Photoelectric Smoke Detector**

**Bases:**

- STB-4SE-EV - Standard deep mounting base
- STB-4SE-24VR - Relay mounting base
- STB-4SE - Standard deep mounting base
- UB-4 - Universal mounting base
- UB-4R-470 - Standard base with 470 ohm resistor
- UB-4SDR-470 - Standard base with schottky diode and 470 ohm resistor
- UB-6-EV - Universal mounting base



Zsuzsanna Major, Certification Engineer

On behalf of BRE Global Assurance (Ireland) Limited

Date of First Issue: 29 October 2019  
Issue Date: 11 February 2026  
Issue Number: 03

To check the validity of this certificate, please contact us on +353 (0) 18824344 or email [enquiries@breglobalireland.ie](mailto:enquiries@breglobalireland.ie)