

BRE Global Ireland

Notified Body No. 2831
 BRE Global Assurance (Ireland) Limited
 DCU Alpha, Old Finglas Road
 Glasnevin, Dublin, D11 KXN4
 Ireland
 T: +353 (0) 18824344
 E: enquiries@breglobalireland.ie
www.breglobalireland.ie

Certificate of constancy of performance 2831-CPR-F2429

In compliance with Regulation (EU) No. 305/2011 of the European Parliament and of the Council of 9th March 2011 (the Construction Products Regulation or CPR), this certificate applies to the construction product(s).

ST-PY-AS Analogue Addressable Photoelectric Smoke Detector

(For full product details and conditions of use refer to appendix)

Placed on the market under the name or trademark of: and produced in the manufacturing plant(s):

Nittan Europe Limited
Hipley Street
Old Woking
Surrey
GU22 9LQ
United Kingdom

CC0365

This certificate attests that all provisions concerning the assessment and verification of constancy of performance described in Annex ZA of the standard(s)

EN 54-7:2018 - Smoke detectors - Point smoke detectors

under system 1 for the performance set out in this certificate are applied and that the factory production control conducted by the manufacturer is assessed to ensure

the constancy of performance of the construction product.

This certificate was first issued on 29 October 2019 and will remain valid as long as neither the harmonised standard, the construction product, the AVCP methods nor the manufacturing conditions in the plant are modified significantly, unless suspended or withdrawn by the notified product certification body.



Zsuzsanna Major, Certification Engineer

Date of First Issue: 29 October 2019

Issue Date: 11 February 2026

On behalf of BRE Global Assurance (Ireland) Limited

Issue Number: 03

To check the validity of this certificate, please contact us on +353 (0) 18824344 or email enquiries@breglobalireland.ie

BRE Global Ireland

Approved Body No. 2831
BRE Global Assurance (Ireland) Limited
DCU Alpha, Old Finglas Road
Glasnevin, Dublin, D11 KXN4
Ireland
T: +353 (0) 18824344
E: enquiries@breglobalireland.ie
www.breglobalireland.ie

APPENDIX to Certificate of constancy of performance: 2831-CPR-F2429

ST-PY-AS Analogue Addressable Photoelectric Smoke Detector

Note:

1. Meets the requirements of EN 54-7 at 'Lowest' and 'Highest' sensitivity settings.

Bases:

STB-4SE - Standard deep mounting base

UB-4 - Universal mounting base

UB-6-EV - Universal mounting base



Zsuzsanna Major, Certification Engineer

On behalf of BRE Global Assurance (Ireland) Limited

Date of First Issue: 29 October 2019

Issue Date: 11 February 2026

Issue Number: 03

To check the validity of this certificate, please contact us on +353 (0) 18824344 or email enquiries@breglobalireland.ie